

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 1 PAGES		
2. AMENDMENT/MODIFICATION NO. R0004		3. EFFECTIVE DATE 01/21/04		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)	
6. ISSUED BY US ARMY ENGINEER DISTRICT, AK CEPOA-CT (DACA85) PO BOX 6898 ANCHORAGE, AK 99506-6898 JUNE WOHLBACH (907)753-5624		CODE J4P0000		7. ADMINISTERED BY (If other than Item 6) US ARMY ENGINEER DISTRICT, AK CEPOA-CO-NAO PO BOX 35066 (BLDG 2104) FAIRBANKS, ALASKA 99703-0066		CODE DACA85	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)			9A. AMENDMENT OF SOLICITATION NO.
				X			DACA85-03-R-0033
							9B. DATED (SEE ITEM 11) 11/20/03
							10A. MODIFICATION OF CONTRACT/ORDER NO.
CODE 089C4				FACILITY CODE			10B. DATED (SEE ITEM 13)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 0 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

PROJECT TITLE AND LOCATION: Security Forces Complex, Eielson AFB, Alaska

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☒ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

PROPOSAL DUE DATE IS 23 JAN 04, 2:00 pm, local time, at the US Army Corps of Engineers, 2204 Third Street, Elmendorf AFB, Alaska.

NOTICE TO OFFERORS: Please mark outside of envelope to show amendment received. You are required to acknowledge receipt of amendments on the reverse side of Standard Form 1442.

A REMINDER THAT ELMENDORF AFB IS STILL UNDER TIGHT SECURITY. BE SURE TO HAVE ALL NECESSARY PAPERWORK NEEDED TO OBTAIN A BASE PASS AND GIVE YOURSELF PLENTY OF TIME TO PROCESS THROUGH THE BONIFACE GATE,

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF SIGNER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

AMENDMENT R0004

General Clarifications:

1. Reference R0003, item 11, Square footage requirement: Per RFP page 246, area is "As needed to support functions; approximately 426SM". It is therefore acceptable to provide less than 426SM so long as functional requirements are met.
2. Reference R0003, item 15, Roof pitch requirement. Rescind in its entirety.
3. Reference R0003, item 18, OSI considerations: Amendment R0003 suggests that the corridor system of the JSF building should consider future expansion. Per Site Visit and Pre-proposal conference minutes, "OSI won't be added on to the building. There's no near possibility of that occurring." This statement was in reference to foundation design and the impact of pounding piles adjacent to the JSF when/if it were to become a reality.

RFP Amendment item:

Section 00100, Tab E, Small Business Subcontracting Plan and Small Business Participation, modify "...within 24 hours of the proposal..." to "...within 1 business day of the proposal..."

Section 01010, pages 132,166 and 215, Finishes, Floor, Change "Sealed concrete" to "Epoxy".

Section 01012, 1.2B, modify 1st and 2nd sentence to allow the government 21 days for review and comment.